

		Master				Slave			
		≤ 20 A		≤ 10 A		≤ 20 A		≤ 10 A	
		X1.1 ≤ 16 A	X1.2 ≤ 8 A	X1.3 ≤ 10 A	X1.4 ≤ 8 A	X1.1 ≤ 16 A	X1.2 ≤ 8 A	X1.3 ≤ 10 A	X1.4 ≤ 8 A
1 RWA-Gruppe	Gesamtausgangsstrom ≤ 60 A	RWA-Gruppe 1							
	Maximalstrom pro Ausgang								
	Lüftungsgruppen								
	1	1				1			
	2	1				2			
	3	1		2		3		4	
	4	1		2		4		5	
	5	1	2	3		3	4	5	
	6	1	2	3	4	4	5	6	7
2 RWA-Gruppen	Gesamtausgangsstrom ≤ 60 A	≤ 20 A		≤ 10 A		≤ 20 A		≤ 10 A	
	Maximalstrom pro Ausgang	X1.1 ≤ 16 A	X1.2 ≤ 8 A	X1.3 ≤ 10 A	X1.4 ≤ 8 A	X1.1 ≤ 16 A	X1.2 ≤ 8 A	X1.3 ≤ 10 A	X1.4 ≤ 8 A
	Lüftungsgruppen	RWA-Gruppe 1				RWA-Gruppe 2			
	2	1				2			
	3	1		2		3		4	
	4	1		2		4		5	
	5	1	2	3		3	4	5	
	6	1	2	3	4	4	5	6	7
	7	1	2	3	4	5	6	7	8
3 RWA-Gruppen	Gesamtausgangsstrom ≤ 60 A	≤ 20 A		≤ 10 A		≤ 20 A		≤ 10 A	
	Maximalstrom pro Ausgang	X1.1 ≤ 16 A	X1.2 ≤ 8 A	X1.3 ≤ 10 A	X1.4 ≤ 8 A	X1.1 ≤ 16 A	X1.2 ≤ 8 A	X1.3 ≤ 10 A	X1.4 ≤ 8 A
	Lüftungsgruppen	RWA-Gruppe 1		RWA-Gruppe 2		RWA-Gruppe 3			
	3	1		2		3			
	4	1		2		3		4	
	5	1	2	3		4		5	
	6	1	2	3	4	5		6	
	7	1	2	3	4	5	6	7	
	8	1	2	3	4	5	6	7	8
4 RWA-Gruppen	Gesamtausgangsstrom ≤ 60 A	≤ 20 A		≤ 10 A		≤ 20 A		≤ 10 A	
	Maximalstrom pro Ausgang	X1.1 ≤ 16 A	X1.2 ≤ 8 A	X1.3 ≤ 10 A	X1.4 ≤ 8 A	X1.1 ≤ 16 A	X1.2 ≤ 8 A	X1.3 ≤ 10 A	X1.4 ≤ 8 A
	Lüftungsgruppen	RWA-Gruppe 1		RWA-Gruppe 2		RWA-Gruppe 3		RWA-Gruppe 4	
	4	1		2		3		4	
	5	1	2	3		4		5	
	6	1	2	3	4	5		6	
	7	1	2	3	4	5	6	7	
5 RWA-Gruppen	Gesamtausgangsstrom ≤ 60 A	≤ 20 A		≤ 10 A		≤ 20 A		≤ 10 A	
	Maximalstrom pro Ausgang	X1.1 ≤ 16 A	X1.2 ≤ 8 A	X1.3 ≤ 10 A	X1.4 ≤ 8 A	X1.1 ≤ 16 A	X1.2 ≤ 8 A	X1.3 ≤ 10 A	X1.4 ≤ 8 A
	Lüftungsgruppen	RWA-Gruppe 1		RWA-Gruppe 2		RWA-Gruppe 3		RWA-Gruppe 4	
	4	1		2		3		4	
	5	1	2	3		4		5	
	6	1	2	3	4	5		6	
	7	1	2	3	4	5	6	7	
6 RWA-Gruppen	Gesamtausgangsstrom ≤ 60 A	≤ 20 A		≤ 10 A		≤ 20 A		≤ 10 A	
	Maximalstrom pro Ausgang	X1.1 ≤ 16 A	X1.2 ≤ 8 A	X1.3 ≤ 10 A	X1.4 ≤ 8 A	X1.1 ≤ 16 A	X1.2 ≤ 8 A	X1.3 ≤ 10 A	X1.4 ≤ 8 A
	Lüftungsgruppen	RWA-Gruppe 1		RWA-Gruppe 2		RWA-Gruppe 3		RWA-Gruppe 4	
	4	1		2		3		4	
	5	1	2	3		4		5	
	6	1	2	3	4	5		6	
	7	1	2	3	4	5	6	7	
7 RWA-Gruppen	Gesamtausgangsstrom ≤ 60 A	≤ 20 A		≤ 10 A		≤ 20 A		≤ 10 A	
	Maximalstrom pro Ausgang	X1.1 ≤ 16 A	X1.2 ≤ 8 A	X1.3 ≤ 10 A	X1.4 ≤ 8 A	X1.1 ≤ 16 A	X1.2 ≤ 8 A	X1.3 ≤ 10 A	X1.4 ≤ 8 A
	Lüftungsgruppen	RWA-Gruppe 1		RWA-Gruppe 2		RWA-Gruppe 3		RWA-Gruppe 4	
	4	1		2		3		4	
	5	1	2	3		4		5	
	6	1	2	3	4	5		6	
	7	1	2	3	4	5	6	7	
8 RWA-Gruppen	Gesamtausgangsstrom ≤ 60 A	≤ 20 A		≤ 10 A		≤ 20 A		≤ 10 A	
	Maximalstrom pro Ausgang	X1.1 ≤ 16 A	X1.2 ≤ 8 A	X1.3 ≤ 10 A	X1.4 ≤ 8 A	X1.1 ≤ 16 A	X1.2 ≤ 8 A	X1.3 ≤ 10 A	X1.4 ≤ 8 A
	Lüftungsgruppen	RWA-Gruppe 1		RWA-Gruppe 2		RWA-Gruppe 3		RWA-Gruppe 4	
	4	1		2		3		4	
	5	1	2	3		4		5	
	6	1	2	3	4	5		6	
	7	1	2	3	4	5	6	7	

		Master				Slave			
		≤ 20 A		≤ 20 A		≤ 20 A		≤ 20 A	
		X1.1 ≤ 16 A	X1.2 ≤ 8 A	X1.3 ≤ 16 A	X1.4 ≤ 8 A	X1.1 ≤ 16 A	X1.2 ≤ 8 A	X1.3 ≤ 16 A	X1.4 ≤ 8 A
1 RWA-Gruppe	Gesamtausgangsstrom ≤ 80 A	RWA-Gruppe 1							
	Maximalstrom pro Ausgang								
	Lüftungsgruppen								
	1	1				1			
	2	1				2			
	3	1		2		3			
	4	1		2		4			
	5	1	2	3		5			
	6	1	2	3	4	6			
2 RWA-Gruppen	Gesamtausgangsstrom ≤ 80 A	≤ 20 A		≤ 20 A		≤ 20 A		≤ 20 A	
	Maximalstrom pro Ausgang	X1.1 ≤ 16 A	X1.2 ≤ 8 A	X1.3 ≤ 16 A	X1.4 ≤ 8 A	X1.1 ≤ 16 A	X1.2 ≤ 8 A	X1.3 ≤ 16 A	X1.4 ≤ 8 A
	Lüftungsgruppen	RWA-Gruppe 1				RWA-Gruppe 2			
	2	1				2			
	3	1		2		3			
	4	1		2		4			
	5	1	2	3		5			
	6	1	2	3	4	6			
	7	1	2	3	4	7			
3 RWA-Gruppen	Gesamtausgangsstrom ≤ 80 A	≤ 20 A		≤ 20 A		≤ 20 A		≤ 20 A	
	Maximalstrom pro Ausgang	X1.1 ≤ 16 A	X1.2 ≤ 8 A	X1.3 ≤ 16 A	X1.4 ≤ 8 A	X1.1 ≤ 16 A	X1.2 ≤ 8 A	X1.3 ≤ 16 A	X1.4 ≤ 8 A
	Lüftungsgruppen	RWA-Gruppe 1		RWA-Gruppe 2		RWA-Gruppe 3			
	3	1		2		3			
	4	1		2		4			
	5	1	2	3		5			
	6	1	2	3	4	6			
	7	1	2	3	4	7			
	8	1	2	3	4	8			
4 RWA-Gruppen	Gesamtausgangsstrom ≤ 80 A	≤ 20 A		≤ 20 A		≤ 20 A		≤ 20 A	
	Maximalstrom pro Ausgang	X1.1 ≤ 16 A	X1.2 ≤ 8 A	X1.3 ≤ 16 A	X1.4 ≤ 8 A	X1.1 ≤ 16 A	X1.2 ≤ 8 A	X1.3 ≤ 16 A	X1.4 ≤ 8 A
	Lüftungsgruppen	RWA-Gruppe 1		RWA-Gruppe 2		RWA-Gruppe 3		RWA-Gruppe 4	
	4	1		2		3		4	
	5	1	2	3		4		5	
	6	1	2	3	4	5		6	
	7	1	2	3	4	6		7	
	8	1	2	3	4	7		8	
		1	2	3	4	8			