



RTC x.y-HEA-HZ-SR:





RTC x.y-HPA-SR:



RTC x.y-HPA-HZ-SR:



RTC x.y-...-SR:

x ... version mounting angle y ... version front plate/glass sheet (variants see ordering designation)



Description of function:

The release valve RTC is a valve which taps a CO2 bottle by pushing the release button, or control of the electromagnet, or the pneumatic release, and so the CO2 can flow to the outlet CA (G1/8").

Releasing:

1) Manual releasing: Deeply press black button.

2) Electric releasing via the electromagnet. (only at HEA and HEA-HZ).

3) Pnematic releasing: Applying the minimum release pressure on PA. (only at HPA and HPA-HZ).

Technical data:

max. operating pressure	80bar
min. control pressure by PA	6bar
nominal width of valve	4mm
nominal width of piercing needle	2mm
rated voltage electromagnet	24VDC
rated current electromagnet	0,29ADC
duty cycle electromagnet	100%
ambient temperature range	-5°C - +55°C

Tolerance Scale 1:2.5 Material						
Created	Sheet	Format	Title	Document Style		
Simetzberger	1/4	A3	Manual release RTC-SR	Data sheet		
Approved	Issue Date			Document State		
HA	02.12.2019			Valid		
Grasi				Document Number 04 011 DAT 37 01-F		





Standard connections:



Option S1:

additional connections at the upperside of valve



Connections:

- CA ... cylinder OPEN
- CZ ... cylinder CLOSE
- PA ... pneumatic remote control



Commissioning the OPEN-release:

- 1) Hook clamping angle into the recess provided (see picture 1).
- 2) Place clamping bolt onto the piercing bolt in the valve.
- 3) Press clamping angle up fully until the piercing bolt engages.
- 4) Check if the piercing needle is located behind the piercing surface of the bottle screw-in thread!
- 5) Check position of the view indicator. View indicator must be on green, if not, press view indicator angle to the valve until view indicator is green (see picture 2)!
- 6) Screw in new CO2 bottle.
- Following releasing, remove empty CO2 bottle (Caution: Residual pressure may be present) and repeat the procress.

Commissioning the close-release:

- 1) Carry out Points 1-4 of the commissioning of the OPEN release accordingly.
- 2) Check position of the priority slide. Both slides must be in the basic position! (see picture 3)
- 3) Screw in new CO2 bottle and close box.
- 4) Following a releasing, remove empty CO2 bottle. (Caution: Residual pressure may be present) and repeat operation.

Installation:

- When using CO2-multi-trip bottles (ascending-tube), mount the valve as per drawing (bottle screwed in from the bottom)
- CAUTION: No dismounting of the valve from the mounting bracket.

Ordering desigantion:



Connection HPA/HPA-HZ-SR:



Tolerance Scale 1:2.5 Material							
Created	Sheet	Format	Title	Document Style			
Simetzberger	2/4	A3	Manual release RTC-SR	Data sheet			
Approved	Issue Da	ite		Document State			
HA	02.12.2019			Valid			
Grasl				Document Number			
Pneumatic Mechanik	Gmbh o	QM FO 05.24.0		04.011.DAT.37.01-E			

Connecting diagramm electromagnet:

